



材料暨工程實驗室-台中



Testing Laboratory

0292

試驗報告



報告編號：TB-18-05151

C-18-13103

頁數：1 OF 1

報告日期：107年09月19日

工程名稱：自測

承包商：-----

委託單位：裕祥地板有限公司

供料廠商：-----

樣品名稱：G-Power生物能量木地板

取樣人員：裕祥地板有限公司

送驗人員：裕祥地板有限公司

取樣日期：107年08月20日

收件日期：107年08月22日

試驗日期：107年08月22日~107年09月17日

備註：1.以上資料由顧客提供(收件及試驗日期除外)

2.除非另有說明，此報告結果僅對測試之樣品負責

未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗結果	方法偵測極限(MDL)	試驗方法
甲醛釋出量-最大值 (mg/L)	N.D.	0.05	CNS 11342(2014)
甲醛釋出量-平均值 (mg/L)	N.D.	0.05	

註：1.試驗樣品厚度為 17 mm

2.試驗結果低於方法偵測極限值(MDL)之測定值以" N.D. "表示；

若高於方法偵測極限值(MDL)，但低於定量極限值(QDL)時，以" < 0.2 "表示，

並括號註明其實測值。

3.N.D. = Not Detected / 未檢出。

----- oOo -----

報告簽署人

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

No. 9, 14th Rd. Taichung Industrial Park, Taichung 40755, Taiwan / 40755 台中市台中工業區14路9號
t (886-4) 2359-1515 f (886-4) 2359-2557 www.sgs.tw

Member of SGS Group

TWC5695007

4005



Material Engineering Laboratory-Taichung



Testing Laboratory

0292

TEST REPORT



Report NO. : TB-18-05151A

C-18-13103

Page NO. : 1 OF 1

Date : Sep. 19, 2018

Project Name : Self Evaluation
Contractor : -----
Applicant : YUSHYANG FLOOR CO., LTD.
Supplier : -----
Sample Name : G-Power The wood with bio-energy
Sample Taken By : YUSHYANG FLOOR CO., LTD.
Sample Submitted By : YUSHYANG FLOOR CO., LTD.
Date of Sampling : Aug. 20, 2018
Date of Sample Received : Aug. 22, 2018
Date of Testing : Aug. 22, 2018 ~ Sep. 17, 2018
Remark : The information mentioned in the above section is provided by Applicant
(Exclude Date of Sample Received and Date of Testing)

Test Results :

Test Item	Test Results	Method Detection Limit (MDL)	Test Method
Emission of formaldehyde-Maximum (mg/L)	N.D.	0.05	CNS 11342(2014)
Emission of formaldehyde-Average (mg/L)	N.D.	0.05	

Note1 : The thickness of the test specimen is 17 mm.

Note2 : If test results are lower than MDL, the N.D. will be shown.

If they are lower than QDL and higher than MDL, the < (0.2) will be shown.

MDL means method detection limit and QDL means quantitation and detection limits.

Note3 : N.D. = Not Detected.

Note4 : This test report is an additional original report of TB-18-05151 C-18-13103. Issued date : Sep. 19, 2018.

-----oOo-----

The required specification(s) offered in this test report is/are for reference only.

The conformity judgment is at the Applicant's final verdict.

Signed for and on behalf of
SGS TAIWAN Ltd.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

No. 9, 14th Rd. Taichung Industrial Park, Taichung 40755, Taiwan / 40755 台中市台中工業區14路9號
t (886-4) 2359-1515 f (886-4) 2359-2557
www.sgs.tw

Member of SGS Group

TWC5695006

4005
t i o n a - t i e n